



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Plzeň

CERTIFICATE

No. 030 – 058838

Basic characteristics of production group

CRYSTAL (fine-grained)

trade name Crystal (grain size less than 2,5 mm), Harmonia

measured values were performed on representative of production group Crystal Diamond

No.	Property	Test method	Unit	Requirements value	Measured value	Average measured value for group CRYSTAL (fine-grained)
1	Apparent density	EN 14617-1	kg/m ³	min. 2 100	2410	2380
2	Water absorption	EN 14617-1	%	max. 0,07	0,03	0,03
3	Flexural Strength	EN 14617-2	MPa	min. 50	63	75
4	Abrasion	EN 14157 (B)	mm ³	max. 7 600	7 099	7099
5	Thermal expansion coefficient (30 to 60°C)	EN 14617-11	10 ⁻⁶ /°C	max. 35	24,7	24,7 – 31,0
	Thermal expansion coefficient (20 to 130°C)	EN 14617-11	10 ⁻⁶ /°C	max. 41	29,9	29,9 – 37,9

Another characteristics

No.	Property	Test method	Unit	Result
1	Reaction to fire	EN 13501-1	class	B / s ₂ / d ₀
2	Frost resistance	EN 14617-5	min. 80	90 - 110
3	Thermal shock resistance	EN 14617-6	-	mechanical characteristics without any change
4	Chemical resistance	EN 14617-10	class	C4
5	Stain resistance	EN ISO 10545-14	class	5
6	Determination of dimensional stability	EN 14617-12	class	A
7	Content of Natural radioactive nuclids and Index mass activity	Declaration under section 101 of paragraph 3 of Act No. 263/2016 of the Collection	-	the value of reference level 1 mSv / year set out in section 102 of paragraph 2 of Decree No 422/2016 of the collection is not exceeded as the natural radionuclide content does not exceed value I = 1
8	Health harmless product	product meets conditions for indoor usage and no volatile organic compounds (VOC) were found; product meets Regulation (EC) No 1935/2004 of the European Parliament and of the Council of 27 October 2004 on materials and articles intended to come into contact with food and repealing and Commission Regulation (EC) No. 10/2011 in latter wording		

The certificate is issued on the basis of the results of the tests in laboratory Technostone and TZUS s.p. branch Plzeň.

Number of pages of certificate: 1

Certificate validity: till 31st August 2024

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Plzeň 1st August 2019



Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Plzeň, Zahradní 15, 326 00 Plzeň, Czech Republic
 ☎: 377 243 331, 📠: 377 430 345, 📠: +420 377 430 347, 📠: +420 377 244 158, ✉ e-mail: kotorova@tzus.cz, www.tzus.cz
 Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679